## LONDON BOROUGH OF HAVERING - HOUSING COMPLIANCE DATE: 1st December 2021

	NUMBER	Sep	Oct	Nov	TREND	TARGET	COMMENTS
FIRE SAFETY COMPLIANCE							
New NODs received		0	1	0	$\Psi$	0	
Outstanding NOD's		3	4	4	<b>&gt;</b>	0	all works in progress
PROPERTIES WITH FRA OR RE-ASSESSED FRA		0.00%	0.00%	100.00%	-	100%	
Cumulative total	920			920	1		
Overdue actions -					-		
A – to be completed within 14 days		0	0	0	⇛	0	
B – to be completed within 6 months		1	1	0	$\Psi$	0	
C – to be completed within 24 months		0	0	0	-	0	
D – to be completed within 5 years		0	0	0	<b>→</b>	0	
Dry Riser Testing		100.00%	100.00%	100.00%	-	100%	
	11	11	11	11			
Fire Alarm Testing		100.00%	100.00%	100.00%	-	100%	
	22	22	22	22			
FRA - PSL							
GAS COMPLIANCE							
Domestic Gas - General Needs		99.99%	99.99%	99.99%	<b>→</b>	100%	
	8574	8573	8566	8567			7 overdue as of the end of November. 5 have since been completed. 1 ongoing legal issue.
Domestic Gas - PSL		100.00%	100.00%	100.00%	-	100%	
	658	658	658	658			

Gas Carcassing		100.00%	100.00%	100.00%	<b>&gt;</b>	100%	
	87	87	87	87			
Communal Gas servicing		100.00%	100.00%	100.00%	-	100%	
	67	67	67	67			
ELECTRICAL COMPLIANCE							
EICRs domestic		83.04%	86.49%	86.75%	1	100%	
	9700	8055	8390	8415			
EICRs domestic – PSL		82.36%	87.73%	87.73%	<b>→</b>	100%	
	701	607	615	615			
EICRs Communal		100.00%	100.00%	100.00%	<b>→</b>	100%	
	861	861	861	861			
Emergency Lighting testing - monthly		100.00%	100.00%	100.00%	-	100%	
	676	676	676	676			
Lightning Protection testing		100.00%	95.35%	95.35%	-	100%	
	43	43	41	41			Kipling and Dryden cannot be completed until external works are completed. Due to be completed December.
PAT Testing		100.00%	100.00%	100.00%		100%	
	49	51	49	49			
LIFT COMPLIANCE							
Monthly maintenance		100.00%	100.00%	100.00%	-	100%	
	19	19	19	19			
Annual servicing		100.00%	100.00%	100.00%	-	100.00%	
	19	19	19	19			
Bi-Annual insurance certificate		100.00%	100.00%	100.00%	-	100%	
	19	19	19	19			
Lift Compliance - PSL					-	100%	

LECIONELLA COMPLIANCE							
LEGIONELLA COMPLIANCE					_		
L8 Legionella Reports - High Risk		100.00%	100.00%	100.00%	<b>≫</b>	100%	
	34	34	34	34			
High Risk Properties on monthly testing programme	21	21	21	21			
High Risk Properties on six monthly testing programme	13	13	13	13			
L8 Legionella Reports - Low Risk		100.00%	100.00%	100.00%	<b>&gt;</b>	100%	
	1430	1430	1430	1430			
Overdue actions from L8 reports							
High - to be completed within 3 months	0	0	0	0	<b>→</b>	0	
Medium – to be completed within 6 months	0	0	0	0	<b>→</b>	0	
Low – to be completed within 12 months	25	12	12	12	<b>→</b>	0	12 outstanding on remedial due to ongoing access issues
L8 Legionella Reports - PSL					<b>→</b>	100%	
L8 Legionella Reports - 2 Year Review Programme		0.00%	98.67%	96.87%	4	100%	
	830		819	804			26 over two year review due to access issues, reviewing our approach
ASBESTOS COMPLIANCE							
Asbestos Surveys - Domestic		38.14%	42.23%	45.57%	1	100%	
	9700	3700	4096	4420			
Asbestos Surveys - Communal		100.00%	100.00%	100.00%	<b>&gt;</b>	100%	
	1138	1138	1138	1138			
Asbestos Surveys - Garages		100.00%	100.00%	100.00%	<b>&gt;</b>	100%	
	143	143	143	143			
Asbestos Surveys - PSL					<b>→</b>	100%	

